

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

# Aeroflex USA, Inc.

232 Industrial Park Road, Sweetwater, TN, United States

For the following product(s):

## **AEROFLEX EPDM™ Closed-Cell Elastomeric Insulation:**

### **Pipe Insulation:**

AEROFLEX Self-Seal™ Tube, AEROFLEX® Unslit Tube, AEROFLEX® Continuous Tube, AEROFLEX® AeroFit™, AEROFLEX® White/Gray Self Seal, AEROFLEX® White/Gray Unslit Tube

### **Sheet & Roll Insulation:**

AEROFLEX® Roll, AEROFLEX® Roll PSA, AEROFLEX® Sheet, AEROFLEX® Sheet PSA



The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## **Indoor Advantage™ Gold**

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.1

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 for the school classroom<sup>1</sup>, private office<sup>1</sup>, and single-family residence<sup>1</sup> parameters.

<sup>1</sup>Modeled Product Type: Insulation

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-IAQ-08084

Valid from: July 21, 2022 to July 20, 2023



Stanley Mathuram, PE, Executive Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA