SOUTHWEST RESEARCH INSTITUTE [®] Chemistry and Chemical Engineering Division Fire Technology Department San Antonio, Texas (210) 522-2638			
Southwest Research Institute (SwRI [®] business and government.) is an independent, nonprofit research and de	evelopment organization founded in 1947 to support industry	
		ection Program established by SwRI as furnishing for the Duc tificate as proof of its compliance, as described below.	
DOCUMENT NO:	22236-01-01	22236-01-01	
PRODUCT:	AEROFLEX Breathe-EZ [™] Duct Insulation		
MANUFACTURED BY:	Aeroflex USA, Inc.		
LOCATION:	Sweetwater, TN		
APPLICATION:	Representative samples have been tested under SwRI Project Nos. 01.27010.02.010 e and b; and 01.27010.02.032a in accordance with procedures and guidelines as shown on the label below.		
LABEL MARK:	The Label shown below is the only one authorized for application to th product.		
Second	SwR	AEROFLEX Breathe-EZ [™] Duct Insulation Duct insulation sheets and rolls Thickness: 1-in. to 2-in. Nominal density: 3-lbs/ft ³ REF 1520 [™] Adhesive Manufactured by Aeroflex USA, Inc.	
	LISTED BY: Southwest Research Institute [®] San Antonio, Texas	in Sweetwater, TN Tested in accordance with ASTM E 84-20 Flame Spread Index < 25 Smoke Developed Index < 50 SwRI® ID No. 22236-01-01	
]		[

SwRI Document of Compliance for AEROFLEX Breathe-EZ[™] Duct Insulation