

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **AEROFLEX USA, INC.**
282 INDUSTRIAL PARK ROAD, SWEETWATER, TN 37874

Category: Construction Materials - Exterior/Interior** Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Content

Accredited Standards & Test Methods: South Coast Air Quality Management District Rule 1168 *low VOC content-adhesives & sealant applications*

*Conforms With: Criteria of MAS Certified Green® Program *low VOC content materials*
LEED v4.1 ID+C, BD+C, Healthcare, Schools *low VOC content materials*
CHPS 2019 Core Criteria 3.0 EQ C6.1.1 *adhesives & sealants- low VOC content*
Material VOC Content *19.0 g/L*
(less water & less exempt compounds)

Certified Products: Aero seal LVOC Adhesive

Test Date: February 21, 2025 Report No.:2500081 Certificate No.: MAS2500081-01R1

Kevin Simpson

Valid: February 2025 to February 2026



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Applied Technical Services, LLC** - ISO/IEC 17025:2017 (A2LA cert. #1888.02)
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

**Compliance designation determined based on interior modeling scenarios and interior VOC Emissions guideline requirements.

Page 1 Of 1